



BID # CHA19-01

ADDENDUM NUMBER 02

REQUEST FOR BIDS FOR:

**Chancellor's Office Data Center Power/Cooling Project at the
Chancellor's Office, 26 College Drive, Concord NH at
New Hampshire Technical Institute, Concord's Community College
February 8, 2019**

TO: ALL CONTRACT BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the Request for Bids dated January 28, 2019 with amendments and additions noted below.

This Addendum consists of a total of two (2) pages.

CLARIFICATIONS TO THE REQUEST FOR PROPOSAL:

Bidders Questions: Questions #6 and #8 have Revised answers:

6. Q: Will the existing Liebert be left in place and included in the N+1 redundant cooling architecture? This will allow one unit to be off and the others will still cool the room.

A: No. The Liebert is not to be considered in the N+1 design.

8. Q: Do you require the new cooling units to have humidification?

A: Yes, as the design has changed. The 20-ton units needs to be the larger ones anyways and those will provide the humidification.

**Acknowledge receipt of this Addendum with the Proposal Form.
Failure to do so may disqualify the Bidder.**

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

Bidder _____

By _____ Date _____
(This Document Must Be Signed)

Name _____
(Please Print or Type Name)

Matthew Moore, P.E.



Director of Capitol Planning & Development
Community College System of New Hampshire
26 College Drive, Concord, N.H. 03301

END OF DOCUMENT