

# COMMUNITY COLLEGE SYSTEM OF NH

26 College Dr  
Concord NH 03301

**ADDENDUM # 01**

**TO BID INVITATION # NHTI20-01**

**FOR: HVAC REPAIRS & BOILER PREVENTATIVE MAINTENANCE**

**DUE: September 11, 2019 at 2:00 pm**

## **Addition to Scope 2:**

**A.5. Glycol to be added at a 50% ratio**

## **Addition to Locations:**

**Langley Hall, 21 Institute Dr.**

**1- Hydrotherm MR2100B**

All other specifications are to remain the same.

**NOTE:** IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER \_\_\_\_\_ ADDRESS \_\_\_\_\_

BY \_\_\_\_\_ DATE \_\_\_\_\_  
(this document must be signed)

\_\_\_\_\_  
(please type or print name) TEL NO. \_\_\_\_\_

BID SUBMISSION TO:  
Stephanie Milender  
NHTI- Concord's Community College  
31 College Drive  
Concord NH 03301  
Email: smilender@ccsnh.edu  
Telephone: 603-230-4126