



BID # RVC 19-02

ADDENDUM NUMBER 01

REQUEST FOR BIDS FOR:

**RVC 19-02 Parking Lot Re-Paving
at River Valley Community College, 1 College Drive, Claremont, NH
a Component of the Community College System of New Hampshire
26 College Drive, Concord, NH**

April 12, 2019

TO: ALL CONTRACT BIDDERS OF RECORD

This Addendum forms a part of the Contract Documents and modifies the Request for Bids dated March 27, 2019 with amendments and additions noted below. This Addendum consists of a total of one (1) page.

CLARIFICATIONS AND QUESTIONS:

- 1) Detail requires 1.5" grind at the milled joints with a 1" overlay with a 24" width.
Ans. Change to 1" grind at the milled joints with a 1" overlay with a 24" width.
- 2) Clarification: The contractor shall sweep in preparation for the liquid tack coat.
- 3) Clarification: The NHDOT Spec is good at .02 Gal/SY on the Tack coat.
- 4) For bidding purposes, bid on a 24" taper into the catch basins for the 1" overlay.

**Acknowledge receipt of this Addendum with the Proposal Form.
Failure to do so may disqualify the Bidder.**

NOTE: IN THE EVENT THAT YOUR BID HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN THE ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

Bidder _____

By _____ Date _____
(This Document Must Be Signed)

Name _____
(Please Print or Type Name)

Matthew Moore, P.E.
Director of Capitol Planning & Development
Community College System of New Hampshire
26 College Drive, Concord, N.H. 0330